



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

1010PAEa-b Housing.

XP/I/1/BCD/Ta = -50°C to +125°C; Type 4X, IP68
DIP/II,III/1/EFG/Ta = -50°C to +125°C; Type 4X, IP68
a = Certifications H, M or BLANK.
b = Threaded entries 01, 02, 03 or 10.

1010PWEa-b Housing.

XP/I/1/BCD/Ta = -50°C to +80°C; Type 4X, IP68
DIP/II,III/1/EFG/Ta = -50°C to +80°C; Type 4X, IP68
a = Certifications H, M or BLANK.
b = Threaded entries 01, 02, 03 or 10.

101aPSEb-c Housing.

XP/I/1/BCD/Ta = -50°C to +125°C; Type 4X, IP68
DIP/II,III/1/EFG/Ta = -50°C to +125°C; Type 4X, IP68
a = Material grade 4 or 6.
b = Certifications H, M or BLANK.
c = Threaded entries 01, 02, 03 or 10.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D and Dust Ignitionproof for Class II, Division 1, Groups E, F and G, Class III, hazardous locations, indoors and outdoors (Type 4X and IP68).

FM Approved for:

Pushna International Inc.
Houston, Texas, USA

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No. 0.4	2009
C22.2 No. 0.5	2008
C22.2 No. 25	2009
C22.2 No. 30	2007
C22.2 No. 94	2011
C22.2 No. 60529	2010

Original Project ID: 3031933C

Approval Granted: June 23, 2008

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3044782	March 26, 2012		

FM Approvals LLC



J.E. Marquedant
Group Manager, Electrical

26 March 2012

Date